

City of Morrow  
Public Works Department

**Back-up Generator**  
**Bid Deadline June 13, 2012 at 2pm**

**Addendum I**

1. The bid specified a 36Kw generator, this addendum will change that specification to a range of 35-40Kw.
2. The bid specified two new 20AMP circuits (one for the B Building and one for the C building), this addendum will change that specification to two 60AMP service portals with 6 circuits each (one for the B Building and one for the A building).
3. The following distances should be added to the specifications:
  - It is 250 feet from the A building (Police Department Administrative Offices) to the C Building (Public Works Building).
  - It is 190 feet from the A Building (Police Department Administrative Offices) to the B Building (Police Department Operations).
  - The pad site for the generator is approximately 90 feet from the gas meter.